

Village of Zeballos

Annual Water Report 2013



Period of monitoring covered by this report: **2013-01-31 to 2013/12/31**

Water supply system operating permit number: **1441048**

Location of water supply system: **Village of Zeballos**

Name of owner(s) **Corporation of the Village of Zeballos**

Name of contact information for person to contact if anyone has questions regarding this report: **Mike Atchison: Public Works Foreman**

During the year 2013 we flushed the system. We had to replace one of SCADA system modules at the reservoir from a lighting strike.

Water Chemical Analysis was last done on 2012/12/12.

Monthly Water Samples are sent to the BC Center for Disease.

During 2013 we had no positive water samples.

2013 we continue to flush system and continue to look for service valves and fix leaks as we find them.

Total Water Consumption 2013: 154.759 m3

Maximum Daily Water Consumption: 437.3 m3

Minimum Daily Water Consumption: 45.9m3

The Village of Zeballos will post this this report on the Village web site.

Report prepared by;

Mike Atchison
Public Works Foreman
Village of Zeballos